

ELECTRICAL CONTINUITY DECLARATION

Producer:	VERGOKAN NV
Reportname:	KBSCL60.---.---
Product description:	Cable tray clickable
Devices under test : (Product references)	KBSCL60.075.075 KBSCL60.200.075 KBSCL60.300.100 KBSCL60.400.100 VM6.10 KBVCL
Test according to:	§ 11.1.2 of the IEC 61537
Description of testmethode:	A current of 25 A \pm 1A A.C. having a frequency of 50 Hz to 60 Hz supplied by a source with a no-load voltage not exceeding 12 V shall be passed through the length of the samples. The voltage drop shall be measured between two points 50 mm each side of the coupler or integral coupling and again between two points 500 mm apart on one side of the joint. The impedances shall not exceed 50 m Ω across the joint and 5 m Ω per meter without the joint.
Manufactured by:	VERGOKAN N.V.
Test device:	HYAMP III 3130
Calibration certificate number:	130624-3130_9352036

[Declaration] :

We declare that above mentioned products are tested by VERGOKAN according to § 11.1.2 of the IEC 61537.


Georges Xhaufaire
Inspector

DESCRIPTION OF TEST:

Test number	Setup	Measuring points	Criteria to pass the test
1	Two cable trays KBSC60.075.075 coupled with click only	On both trays 50mm of the coupling.	Impedance can not exceed 50mΩ
2	Two cable trays KBSC60.200.075 coupled with click only	On both trays 50mm of the coupling.	Impedance can not exceed 50mΩ
3	Two cable trays KBSC60.300.100 coupled with click only	On both tray's 50mm of the coupling.	Impedance can not exceed 50mΩ
4	Two cable trays KBSC60.400.100 coupled with click only	On both trays 50mm of the coupling.	Impedance can not exceed 50mΩ
5	Two cable trays KBSC60.075.075 coupled with VM6.10	On both tray's 50mm of the coupling.	Impedance can not exceed 50mΩ
6	Two cable trays KBSC60.200.075 coupled with VM6.10	On both tray's 50mm of the coupling.	Impedance can not exceed 50mΩ
7	Two cable trays KBSC60.300.100 coupled with VM6.10	On both tray's 50mm of the coupling.	Impedance can not exceed 50mΩ
8	Two cable trays KBSC60.400.100 coupled with VM6.10	On both tray's 50mm of the coupling.	Impedance can not exceed 50mΩ
9	Two cable trays KBSC60.075.075 coupled with KBVCL	On both tray's 50mm of the coupling.	Impedance can not exceed 50mΩ
10	Two cable trays KBSC60.200.075 coupled with KBVCL	On both tray's 50mm of the coupling.	Impedance can not exceed 50mΩ
11	Two cable trays KBSC60.300.100 coupled with KBVCL	On both tray's 50mm of the coupling.	Impedance can not exceed 50mΩ
12	Two cable trays KBSC60.400.100 coupled with KBVCL	On both tray's 50mm of the coupling.	Impedance can not exceed 50mΩ
13	KBSC60.075.075	On the tray, 500mm apart from each other	Impedance can not exceed 5mΩ/m
14	KBSC60.200.100	On the tray, 500mm apart from each other	Impedance can not exceed 5mΩ/m
15	KBSC60.300.100	On the tray, 500mm apart from each other	Impedance can not exceed 5mΩ/m
16	KBSC60.400.100	On the tray, 500mm apart from each other	Impedance can not exceed 5mΩ/m

RESULTS OF TEST:



Georges Xhaufaire
 Inspector

Test number	Test	Impedance	Result
1	1	4 mΩ	Pass
	2	3 mΩ	Pass
	3	3 mΩ	Pass
2	1	2 mΩ	Pass
	2	2 mΩ	Pass
	3	2 mΩ	Pass
3	1	2 mΩ	Pass
	2	2 mΩ	Pass
	3	2 mΩ	Pass
4	1	4 mΩ	Pass
	2	4 mΩ	Pass
	3	4 mΩ	Pass
5	1	2 mΩ	Pass
	2	2 mΩ	Pass
	3	2 mΩ	Pass
6	1	2 mΩ	Pass
	2	2 mΩ	Pass
	3	2 mΩ	Pass
7	1	2 mΩ	Pass
	2	2 mΩ	Pass
	3	2 mΩ	Pass
8	1	4 mΩ	Pass
	2	4 mΩ	Pass
	3	3 mΩ	Pass
9	1	7 mΩ	Pass
	2	7 mΩ	Pass
	3	7 mΩ	Pass
10	1	2 mΩ	Pass
	2	2 mΩ	Pass
	3	2 mΩ	Pass
11	1	5 mΩ	Pass
	2	5 mΩ	Pass
	3	5 mΩ	Pass
12	1	5 mΩ	Pass
	2	6 mΩ	Pass
	3	5 mΩ	Pass
13	1	2 mΩ	Pass
	2	2 mΩ	Pass
	3	2 mΩ	Pass
14	1	2 mΩ	Pass
	2	2 mΩ	Pass
	3	2 mΩ	Pass
15	1	2 mΩ	Pass
	2	2 mΩ	Pass
	3	2 mΩ	Pass
16	1	2 mΩ	Pass
	2	2 mΩ	Pass
	3	2 mΩ	Pass



CONCLUSION:

All the devices under test where tested as described above and did meet their criteria to pass the test.
We can state that the cable tray KBSCL60.---.-- is conform to § 11.1.2 of the IEC 61537.

Oudenaarde, 12/06/2019



Gino Declercq
Operations Director

On condition that the product(s) is/are used in the manner intended and/or in accordance with the current installation standards and/or with the manufacturer's recommendations.



Georges Xhaufaire
Inspector