

ELECTRICAL CONTINUITY DECLARATION

Producer:	VERGOKAN NV
Reportname:	NEO+VGLI
Product description:	Universal floorbox
Devices under test : (Productreferences)	NEO VGLI
Test according to:	§ 11.1.2 of the IEC 61537
Description of testmethode:	A current of 25 A ± 1A A.C. having a frequency of 50 Hz to 60 Hz supplied by a source with a no-load voltage not exceeding 12 V shall be passed through the length of the samples. The voltage drop shall be measured between two points 50 mm each side of the coupler or integral coupling and again between two points 500 mm apart on one side of the joint. The impedances shall not exceed 50 mΩ across the joint and 5 mΩ per meter without the joint.
Manufactured by:	VERGOKAN N.V.
Test device:	HYAMP III 3130
Calibration certificate number:	130624-3130_9352036

[Declaration] :

We declare that above mentioned products are tested by VERGOKAN according to § 11.1.2 of the IEC 61537.



DESCRIPTION OF TEST:

Test number	Setup	Measuring points	Criteria to pass the test
1	NEO coupled with VGLI	On both products 50mm of the coupling.	Impedance can not exceed 50mΩ
2	NEO coupled with VGLI	On both products 50mm of the coupling.	Impedance can not exceed 50mΩ
3	NEO coupled with VGLI	On both products 50mm of the coupling.	Impedance can not exceed 5mΩ/m

RESULTS OF TEST: (test performed March 5, 2024)

Test number	Test	Impedance	Result
1	1	5 mΩ	Pass
	2	5 mΩ	Pass
	3	4 mΩ	Pass
2	1	4 mΩ	Pass
	2	5 mΩ	Pass
	3	4 mΩ	Pass
3	1	4 mΩ	Pass
	2	4 mΩ	Pass
	3	5 mΩ	Pass

CONCLUSION:

All the devices under test were tested as described above and did meet their criteria to pass the test. **We can state that the NEO with VGLI.---is conform to § 11.1.2 of the IEC 61537.**

Oudenaarde, March 6, 2024

Gino Declercq
Managing Director



On condition that the product(s) is/are used in the manner intended and/or in accordance with the current installation standards and/or with the manufacturer's recommendations.

