

---

**ELECTRICAL CONTINUITY DECLARATION**

---

Producer:	VERGOKAN NV
Reportname:	(HD)KBS 110*---*---
Product description:	Perforated cable tray 110
Devices under test :	KBS 110*150*1.25
(Product references)	KBS 110*600*1.50 V 110*200 VM 6*10 HDKBS 110*150*1.25 HDKBS 110*600*1.50 HDV 110*200 HDVM 6*10
Test according to:	§ 11.1.2 of the IEC 61537
Description of testmethode:	A current of 25 A $\pm$ 1A A.C. having a frequency of 50 Hz to 60 Hz supplied by a source with a no-load voltage not exceeding 12 V shall be passed through the length of the samples. The voltage drop shall be measured between two points 50 mm each side of the coupler or integral coupling and again between two points 500 mm apart on one side of the joint. The impedances shall not exceed 50 m $\Omega$ across the joint and 5 m $\Omega$ per meter without the joint.
Manufactured by:	VERGOKAN N.V.
Test device:	HYAMP II I3130
Calibration certificate number:	130624-3130_9352036

**[Declaration] :**

*We declare that above mentioned products are tested by VERGOKAN according to § 11.1.2 of the IEC 61537.*



**DESCRIPTION OF TEST:**

Test number	Setup	Measuring points	Criteria to pass the test
1	Two cable trays KBS 110*150*1.25 coupled with V110*200 and VM 6*10	On both trays 50mm of the coupling.	Impedance can not exceed 50mΩ
2	Two cable trays KBS 110*600*1.50 coupled with V110*200 and VM 6*10	On both tray's 50mm of the coupling.	Impedance can not exceed 50mΩ
3	Two cable trays HDKBS 110*150*1.25 coupled with HDV110*200 and HDVM 6*10	On both trays 50mm of the coupling.	Impedance can not exceed 50mΩ
4	Two cable trays HDKBS 110*600*1.50 coupled with HDV110*200 and HDVM 6*10	On both tray's 50mm of the coupling.	Impedance can not exceed 50mΩ
5	KBS 110*150*1.25	On the tray, 500mm apart from each other	Impedance can not exceed 5mΩ/m
6	KBS 110*600*1.50	On the tray, 500mm apart from each other	Impedance can not exceed 5mΩ/m
7	HDKBS 110*150*1.25	On the tray, 500mm apart from each other	Impedance can not exceed 5mΩ/m
8	HDKBS 110*600*1.50	On the tray, 500mm apart from each other	Impedance can not exceed 5mΩ/m

**RESULTS OF TEST:**

Test number	Test	Impedance	Result
1	1	1 mΩ	Pass
	2	1 mΩ	Pass
	3	1 mΩ	Pass
2	1	1 mΩ	Pass
	2	1 mΩ	Pass
	3	1 mΩ	Pass
3	1	1 mΩ	Pass
	2	1 mΩ	Pass
	3	1 mΩ	Pass
4	1	2 mΩ	Pass
	2	2 mΩ	Pass
	3	2 mΩ	Pass
5	1	1 mΩ	Pass
	2	1 mΩ	Pass
	3	1 mΩ	Pass
6	1	1 mΩ	Pass
	2	1 mΩ	Pass
	3	1 mΩ	Pass
7	1	1 mΩ	Pass
	2	1 mΩ	Pass
	3	1 mΩ	Pass



8	1	1 mΩ	Pass
	2	2 mΩ	Pass
	3	1 mΩ	Pass

**CONCLUSION:**

All the devices under test where tested as described above and did meet their criteria to pass the test.  
**We can state that the cable trays KBS110\*---\*--- and HDKBS 110\*---\*--- are conform to § 11.1.2 of the IEC 61537.**



Thomas Leus  
Operations Director

Oudenaarde, 12/11/2013

*\* Pictures of the test setup canbe obtainedon request*

On condition that the product(s) is/are used in the manner intended and/or in accordance with the current installation standards and/or with the manufacturer's recommendations.