

ELECTRICAL CONTINUITY DECLARATION

Producer:	VERGOKAN NV
Reportname:	INOXKL 60*---
Product description:	Cable ladder
Devices under test : (Product references)	INOXKL 60*200 INOXKL 60*600 INOXV 60*200 INOXVM 6*10
Test according to:	§ 11.1.2 of the IEC 61537
Description of testmethode:	A current of 25 A \pm 1A A.C. having a frequency of 50 Hz to 60 Hz supplied by a source with a no-load voltage not exceeding 12 V shall be passed through the length of the samples. The voltage drop shall be measured between two points 50 mm each side of the coupler or integral coupling and again between two points 500 mm apart on one side of the joint. The impedances shall not exceed 50 m Ω across the joint and 5 m Ω per meter without the joint.
Manufactured by:	VERGOKAN N.V.
Test device:	HYAMP III 3130
Calibration certificate number:	130624-3130_9352036

[Declaration] :

We declare that above mentioned products are tested by VERGOKAN according to § 11.1.2 of the IEC 61537.



DESCRIPTION OF TEST:

Test number	Setup	Measuring points	Criteria to pass the test
1	Two cable ladders INOXKL 60*200 coupled with INOXV 60*200 and INOXVM 6*10	On both trays 50mm of the coupling.	Impedance can not exceed 50mΩ
2	Two cable trays INOXKL 60*600 coupled with INOXV 60*200 and INOXVM 6*10	On both tray's 50mm of the coupling.	Impedance can not exceed 50mΩ
3	INOXKL 60*200	On the tray, 500mm apart from each other	Impedance can not exceed 5mΩ/m
4	INOXKL 60*600	On the tray, 500mm apart from each other	Impedance can not exceed 5mΩ/m

RESULTS OF TEST:

Test number	Test	Impedance	Result
1	1	4 mΩ	Pass
	2	4 mΩ	Pass
	3	4 mΩ	Pass
2	1	4 mΩ	Pass
	2	4 mΩ	Pass
	3	4 mΩ	Pass
3	1	5 mΩ	Pass
	2	4 mΩ	Pass
	3	4 mΩ	Pass
4	1	4 mΩ	Pass
	2	4 mΩ	Pass
	3	5 mΩ	Pass

CONCLUSION:

All the devices under test where tested as described above and did meet their criteria to pass the test.

We can state that the cable ladder INOXKL 60*--- is conform to § 11.1.2 of the IEC 61537.



Oudenaarde, 12/11/2013

Thomas Leus
Operations Director

* Pictures of the test setup can be obtained on request

On condition that the product(s) is/are used in the manner intended and/or in accordance with the current installation standards and/or with the manufacturer's recommendations.